# **MODEL AGG**

SD-AGG-17.10 Page 1

Round Damper • 71/2" Deep • Single Thickness Blade • Volume Control • For Low Leakage • Galvanized Steel

# For use to 6 in. w.g. and 3000 FPM

### Standard Construction and Materials

FRAME: 22 GA. galvanized steel, 71/2" deep with reinforcing ribs.

BLADE: 20 GA. galvanized steel, double thickness.

**SHAFT:** ½" dia. plated steel stub, mono-bolted to blade. Extends 6" beyond frame.

**BEARINGS:** Bronze oilite flanged sleeve, press fit to frame.

STOPS: Formed galvanized steel angle mechanically fastened to the frame to prevent over

rotation of the blade.

ACTUATOR: 1/16" thk. Neoprene rubber, riveted to the blade with a 20 GA. galvanized steel

retaining plate.

TEMP LIMIT: 250°F. FINISH: Mill.


#### Notes


- 1. Nominal deductions will be made to the opening size given.
- 2. Round dampers are available in 1" increments only.
- 3. This damper is designed for low leakage applications.
- 4. The rolled ribs in the frame provide greater reinforcement, ease of installation, and a sealing joint.
- 5. To calculate approximate shipping weight (lbs./in.), use the following formula:

Diameter (in.) × 0.47 (lbs./in.)

## Damper Sizes

Min Dia.	Max Dia.			
4" O.D.	24" O.D.			





ltem #	Qty	Damper Size	Tagging		Remarks			
Item#	Ciy	O.D.						<u>Union Made</u>
Arch.	/ Eng.:		EDR:		ECN:		Job:	
Cont	ractor:							
Р	roject:		Date:		DWN:		DWG:	

In the interest of product development, Cesco Products reserves the right to make changes without notice.




450 Riverside Dr • Wyalusing PA, 18853 Phone: 570-746-1888 • Fax: 570-746-9286 www.cescoproducts.com


Round Damper • 7½" Deep • Single Thickness Blade • Volume Control • For Low Leakage • Galvanized Steel

#### Performance Data

Pressure drop ratings are based on AMCA Standard 500 using test set-up figure 5.3 for a damper installed with duct upstream and downstream. Static pressures are corrected to .075 lb./cu.ft. air density.



Air Leakage ratings are based on AMCA Standard 500 using test set-up figure 5.4. Air Leakage is corrected to .075 lb./cu.ft. air density.





450 Riverside Dr • Wyalusing PA, 18853 Phone: 570-746-1888 • Fax: 570-746-9286 www.cescoproducts.com