Standard Construction and Materials

FRAME: .125" thick (nominal) extruded aluminum. **BLADE:** .125" thick (nominal) extruded aluminum.

SCREEN: ¹⁸/₁₆ Mesh, .011" dia. aluminum wire, insect screen.

FINISH: Clear anodized finish is standard.


Options

Finish - Baked Enamel, Kynar, Anodize


Notes

- 1. Nominal deductions will be made from opening dimensions given unless otherwise stated.
- 2. Many stock sizes are available for immediate shipment. Brick vents are also available in practically any width or height.

| | · | | |
|---------------|---------------|-----------|--|
| Ordered Size | Minimum | Free Area | |
| | Opening Size | (Sq. In.) | |
| 12" x 4¾" | 12¼" x 5¼" | 17.28 | |
| 12" x 2¾" | 12¼" x 2¾" | 6.34 | |
| 81/8" x 23/8" | 83/8" x 27/8" | 4.18 | |
| 81/8" x 43/4" | 83/8" x 51/4" | 11.52 | |
| 81/8" x 73/4" | 83/8" x 81/4" | 19.58 | |
| 16½" x 2¾" | 16¾" x 2¾" | 8.64 | |
| 16½" x 4¾" | 16¾" x 5¼" | 28.22 | |
| 16½" x 7¾" | 16¾" x 8¼" | 40.32 | |
| 24" x 4¾" | 24¼" x 5¼" | 39.02 | |
| 24" x 7¾" | 24¼" x 8¼" | 58.75 | |




For custom size Brick Vents, contact customer service for details.



Straight Ducts

Fastened securely to vent 24 GA. galvanized steel standard. Specify wall thickness ("A" dimension)



"Z" Ducts

Fastened securely to vent 24 GA. galvanized steel standard. Use when space to be vented is below grade. Provide dimensions "A", "B", and "C".

For handwritten orders, use the schedule block on page 2. In the interest of product development, Cesco Products reserves the right to make changes without notice.



September 2020

Standard Brick Vents

SD-588-20.09

Brick Vent • 4" Deep • 45° Straight Blades • Stationary • Extruded Aluminum

Page 2

| Item | Ohr | Opening Size | | Finish | Touring | Not Free | Total |
|------|-----|--------------|--------------|--------|---------|----------|-------|
| | Qty | Width ("A") | Height ("B") | Finish | Tagging | Net Each | Total |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

