

KNSX V3 BACnet Configuration

Revision History

Version 1.20 – 10/3/2019

- 1) Added Local Flow sensor Input Register

Version 1.13 (3/7/2017)

Fixed an issue with reading/writing negative values for OARLowAirTemp.

Version 1.12 (11/5/2014)

- 1) Fixed an issue that prevented reading many of the status bits for boilers 9 – 16.

Version 1.10 (7/2/2014)

- 1) Added BTUH (analog_input)
- 2) Added SystemReturnTemp (analog_input)
- 3) Added SystemFlow (analog_input)
- 4) Added HeatingBoilersOn (analog_input)
- 5) Added DHWBoilersOn (analog_input)
- 6) Added ManualBoilersOn (analog_input)
- 7) Added Boiler##_StackSensorNA (binary_variable)
- 8) 8) Added Boiler##_SysReturnSensorNA (binary_variable)

Version 1.00

Initial Release