

Brick Vents Standard Frame

STANDARD MATERIALS AND CONSTRUCTION

FRAME: .125" thick (nominal) extruded aluminum.

BLADE: .125" thick (nominal) extruded aluminum.

SCREEN: 1 $\frac{1}{2}$ Mesh, .011" dia. aluminum wire, insect screen.

FINISH: Clear anodized finish is standard.

OPTIONS


Finish - Baked Enamel, Kynar, Anodize

NOTES


1. Nominal deductions will be made from opening dimensions given unless otherwise stated.
2. Many stock sizes are available for immediate shipment. Brick vents are also available in practically any width or height.

BRICK VENT SIZES

Ordered Size	Minimum Opening Size	Free Area (Sq. In.)
12" x 4 $\frac{3}{4}$ "	12 $\frac{1}{4}$ " x 5 $\frac{1}{4}$ "	17.28
12" x 2 $\frac{3}{8}$ "	12 $\frac{1}{4}$ " x 2 $\frac{7}{8}$ "	6.34
8 $\frac{1}{8}$ " x 2 $\frac{3}{8}$ "	8 $\frac{3}{8}$ " x 2 $\frac{7}{8}$ "	4.18
8 $\frac{1}{8}$ " x 4 $\frac{3}{4}$ "	8 $\frac{3}{8}$ " x 5 $\frac{1}{4}$ "	11.52
8 $\frac{1}{8}$ " x 7 $\frac{3}{4}$ "	8 $\frac{3}{8}$ " x 8 $\frac{1}{4}$ "	19.58
16 $\frac{1}{2}$ " x 2 $\frac{3}{8}$ "	16 $\frac{3}{4}$ " x 2 $\frac{7}{8}$ "	8.64
16 $\frac{1}{2}$ " x 4 $\frac{3}{4}$ "	16 $\frac{3}{4}$ " x 5 $\frac{1}{4}$ "	28.22
16 $\frac{1}{2}$ " x 7 $\frac{3}{4}$ "	16 $\frac{3}{4}$ " x 8 $\frac{1}{4}$ "	40.32
24" x 4 $\frac{3}{4}$ "	24 $\frac{1}{4}$ " x 5 $\frac{1}{4}$ "	39.02
24" x 7 $\frac{3}{4}$ "	24 $\frac{1}{4}$ " x 8 $\frac{1}{4}$ "	58.75




For custom size Brick Vents, contact customer service for details.



Straight Ducts

Fastened securely to vent 24 GA. galvanized steel standard. Specify wall thickness ("A" dimension)



"Z" Ducts

Fastened securely to vent 24 GA. galvanized steel standard. Use when space to be vented is below grade. Provide dimensions "A", "B", and "C".

Please use the Brick Vent order form on the next page for handwritten orders.

In the interest of product development, Airline Louvers reserves the right to make changes without notice.

Item #	Qty	Width	Height	Width	Height	Mullion	Type	Location	Intake	Exhaust	
		Opening Size		Louver Size			Screens		Louver Type		
Arch. / Eng. :						EDR:		ECN:		Job:	
Contractor:											
Project:						Date:		DWN:		DWG:	

1020 Prince Frederick Blvd. Suite 305 • Prince Frederick, MD 20687 • Phone: (570) 420-7079 • Fax: (570) 420-7078

